

RULE D  
METERING

1. Meter Installations. The Company will install and maintain the metering equipment required by the Company to measure power and energy supplied to the Customer. Meter installations will be done at the Company's expense except as specified below or otherwise specified in a schedule. Customer provisions for meter installations will be made in conformance with Company specifications, the National Electrical Code, and/or applicable state or municipal requirements.

a. Instrument Transformer Metering. When instrument transformer metering is requested by the Customer but not required by the Company at the time of the initial meter installation, the Customer will be required to pay the cost of such metering equipment and its installation in accordance with the charges specified in Schedule 66. When a Customer requests instrument transformer metering not required by the Company at a time other than at the time of the initial meter installation, the actual costs will apply.

b. Off-Site Meter Reading Service. Customers taking single-phase service under Schedule 1, 4, 5, or 7 may request the Company install metering equipment which provides for off-site meter reading. The installation fee and monthly charges for off-site meter reading capability, when the service is requested by the Customer but not deemed to be cost-effective by the Company, are specified in Schedule 66. The Company shall have the sole right to determine whether an installation is cost-effective. Customers who request the Company-installed off-site meter reading equipment be removed within 90 days of initial installation will be assessed a removal fee in accordance with the provisions of Schedule 66. Due to the specialized nature of the metering equipment, a delay may occur between the time a Customer requests the Off-Site Meter Reading Service and the time the equipment is available for installation. Customers utilizing the Off-Site Meter Reading Service may be required to periodically permit Company personnel access to the meter in order for maintenance to be performed.

c. Load Profile Metering. The Company will install, at the Customer's request, the metering equipment necessary to provide load profile information. The installation fee and monthly charges for load profile capability, when the service is requested by the Customer but not provided by the Company as part of the standard meter installation, are specified in Schedule 66. The options available under the Load Profile Metering Service include Meter Pulse Output Service, Load Profile Recording Service, and Enhanced Metering Information Service. Customers requesting the Load Profile Recording Service are responsible for providing, at their own expense, a hard-wired phone line to each metering point. Customers who request the Load Profile Metering Service be discontinued within 36 months of initial installation will be assessed a removal fee in accordance with the provisions of Schedule 66.

d. Surge Protection Device Services. At the Customer's request, the following services are available for watt-hour metered Customers only.

i. Installation or Removal. The Company will install or remove, at the Customer's request, a surge protection device supplied by the Customer on the meter base and other utility peripherals to accommodate whole-house surge protection. A Surge Protection Device Installation or Removal Charge will be assessed as specified in Schedule 66.

RULE C  
SERVICE AND LIMITATIONS  
(Continued)

5. Point of Delivery Service Requirements (Continued)

Where separate Points of Delivery exist for supplying service to a Customer at a single Premises or separate meters are maintained for measurement of service to a Customer at a single Premises, the meter readings will not be combined or aggregated for any purpose except for determining if the Customer's total power requirements exceed 20,000 kW. Special contract arrangements will be required when a Customer's aggregate power requirement exceeds 20,000 kW.

Service delivered at low voltage (600 volts or under) will be supplied from the Company's distribution system to the outside wall of the Customer's building or service pole, unless an exception is granted by the Company and the City or State Electrical Inspector.

The Customer's facilities will be installed and maintained in accordance with the requirements of the National Electrical Code.

6. Limitation of Use. A Customer will not resell electricity received from the Company to any person except where the Customer is owner, lessee, or operator of a commercial building, shopping center, apartment house, mobile home court, or other multi-family dwelling where the use has been sub-metered prior to July 1, 1980, and the use is billed to tenants at the same rates that the Company would charge for service, unless the Commission authorizes alternative procedures.

A Customer's wiring will not be extended or connected to furnish service to more than one building or place of use through one meter, even though such building, property, or place of use is owned by the Customer. This rule is not applicable where the Customer's residence or business consists of one or more adjacent buildings or places of use located on the same Premises or operated as an integral unit, under the same name and carrying on parts of the same residence or business.

7. Rights of Way. The Customer shall, without cost to the Company, grant the Company a right of way for the Company's lines and apparatus across and upon the property owned or controlled by the Customer, necessary or incidental to the supplying of Electric Service and shall permit access thereto by the Company's employees at all reasonable hours.